NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROP & POWER REQUIREMENTS

CKT AV2: 2ND FLOOR DESCRIPTION	QTY	CURRENT PER ITEM (AMPS)	TOTAL CURRENT PER ITEM		
WHEELOCK STROBE 15 cd	_	0.5010	0.0000		
WHEELOCK HORN/STROBE 15cd	_	0.0000	0.0000		
WHEELOCK STROBE 30 cd	-	0.0300	0.0000		
WHEELOCK HORN/STROBE 30 cd	_	0.0450	0.0000		
WHEELOCK STROBE 75 cd	_	0.1650	0.0000		
WHEELOCK HORN/STROBE 75 cd	_	0.1100	0.0000		
WHEELOCK STROBE 110 cd	4	0.2200	0.8800		
WHEELOCK HORN/STROBE 110 cd	3	0.3070	0.9210		
WHEELOCK HORN	1	0.0000	0.0000		
AUTOCALL BELL	4	0.0500	0.2000		
AUTOCALL BELL/STROBE 75 cd	1	0.2150	0.0000		
TOTAL NOTIFICATION APPLIANCES CURRENT					
VOLTAGE DROP (VD) CALCULATIONS	WIRE	CIRCULAR			
$VD = \{(I) (D) (21.6)\}/CM$	SIZE	MILS			
WHERE: I = CIRCUIT CURRENT D = CONDUCTOR LENGTH (FT) ONE WAY	12AWG	6530			
21.6 = CONSTANT	14AWG	4110			
CM = WIRE CROSS-SECTIONAL AREA (CIRCULAR MIL	16AWG	2580			
$VD = {(2.001A) (440FT) (21.64)}/4110 = 4.627V$	18AWG	1620			
$%VD = \{4.627V / 24V\} X 100 = 19.28\%$	20AWG	1020			
REMAINING VOLTS = 19.373			<u> </u>		

BATTERY CALCULATIONS FAP-001-80

ITEM	DESCRIPTION	QTY	STANDBY CURRENT PER ITEM (AMPS)	TOTAL STANDBY CURRENT PER ITEM	ALARM CURRENT PER ITEM (AMPS)	TOTAL ALARM CURRENT PER ITEM
CP-35	FACP w/2ZN'S + AUD	1	0.1750	0.1750	0.5010	0.5010
PS-35	POWER SUPPLY	1	0.0000	0.0000	0.0000	0.0000
BC-35	BATTERY CHARGER	1	0.0450	0.0450	0.0300	0.0300
AA-30U	CLASS B BELL MODULE	1	0.0065	0.0065	0.0400	0.0400
PM-32	MATRIX MODULE	1	0.0000	0.0000	0.0000	0.0000
RM-30U	RELEASE MODULE	_	0.0050	0.0000	1.5000	0.0000
SM-30	SWITCH MODULE	3	0.0000	0.0000	0.0450	0.1350
SR-32	6 RELAY MODULE	_	0.0000	0.0000	0.0450	0.0000
SR-35	8 RELAY MODULE	2	0.0000	0.0000	0.0210	0.0420
TC-30U	BATTERY TRANSFER	_	0.0000	0.0000	0.0500	0.0000
TL-30U	TIME LIMIT	_	0.0300	0.0000	0.0150	0.0000
ZN-34US	SUPERVISORY MODULE	3	0.0100	0.0300	0.1100	0.3300
ZU-35	ZONE MODULE	1	0.0090	0.0090	0.1100	0.1100
ZU-35DS	ZONE MODULE/SD's	5	0.0090	0.0450	0.1100	0.5500
SMOKE	SMOKE DETECTOR	34	0.0034	0.0003	0.0010	0.0340
MOI	TRANSMITTER	1	0.1200	0.1200	0.1750	0.1750
MID	INPUT BOARD	2	0.0020	0.0040	0.0000	0.0000
PS-5A	POWER SUPPLY	1	0.0380	0.0380	0.0000	0.0000
TOTAL NOTIFICATION APPLIANCES CURRENT					3.5510	
	TOTAL SYSTEM CUR	RENT	STANDBY	0.5559	ALARM	5.8230

MIN. BATTERY CAPACITY = $\{(TOT. STANDBY CURRENT X STANDBY TIME) +$

(TOT. ALARM CURRENT X ALARM TIME)} X 1.25

MIN. BATTERY CAPACITY = $\{(0.5559 \text{ A X } 24 \text{ HR}) + (5.823 \text{ A X } 0.083 \text{ HR})\} \text{ X } 1.25$ MIN. BATTERY CAPACITY = {13.3416 AHr + 0.4833 AHr} X 1.25 = 17.2811 AHr

NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROP & POWER REQUIREMENTS

CKT AV1: BASEMENT & 1ST FLR DESCRIPTION	QTY	CURRENT PER ITEM (AMPS)	TOTAL CURRENT PER ITEM
WHEELOCK STROBE 15 cd	_	0.5010	0.0000
WHEELOCK HORN/STROBE 15cd	_	0.0000	0.0000
WHEELOCK STROBE 30 cd	_	0.0300	0.0000
WHEELOCK HORN/STROBE 30 cd	_	0.0450	0.0000
WHEELOCK STROBE 75 cd	_	0.165	0.0000
WHEELOCK HORN/STROBE 75 cd	_	0.1100	0.0000
WHEELOCK STROBE 110 cd	5	0.2200	1.1000
WHEELOCK HORN/STROBE 110 cd	_	0.1750	0.0000
WHEELOCK HORN	_	0.0000	0.0000
AUTOCALL BELL	9	0.0500	0.0450
AUTOCALL BELL/STROBE 75 cd	_	0.2150	0.0000
TOTAL NOTIFICATION APPLIANCES CURRENT			1.5500
VOLTAGE DROP (VD) CALCULATIONS		WIRE	CIRCULA
$VD = \{(I) (D) (21.6)\}/CM$		SIZE	MILS
WHERE: I = CIRCUIT CURRENT D = CONDUCTOR LENGTH (FT) ONE WAY			6530
21.6 = CONSTANT	14AWG	4110	
CM = WIRE CROSS-SECTIONAL AREA (CIRCULAR MILS)			2580
$VD = {(1.55) (420FT) (21.64)}/4110 = 3.421V$			1620
$%VD = {3.421V / 24V} X 100 = 14.255\%$	20AWG	1020	
REMAINING VOLTS = 20.579			

PROFESSIONAL SEAL (IF REVISION, APPLIES ONLY TO REVISED WORK)

FIRE ALARM SYSTEM FUNCTION CHART SYSTEM EVENT	ANNUNCIATE AT FACU	FIRE SIGNAL TO RECEIVER	TROUBLE SIGNAL TO LBNL RECEIVER	SUPERVISORY SIGNAL TO LBNL RECEIVER	DPERATE 80,80A NOTIFICATION DEVICES	ELEVATOR RECALL	DAMPER RELEASE	AHU-6 SHUTDOWN	ROLL-UP DOOR RELEASE
80,80A FIRE CALL BOXES	•	•			•	•			
80 HEAT DETECTORS	•	•			•	•			
80 FACP SMOKE DETECTOR	•	•			•	•			
80 (AHU-6) DUCT SMOKE DETECTOR	•	•			•	•	•	•	
80 ELEVATOR SMOKE DETECTORS	•	•			•	•			
80-109 ROLL-UP DOOR SMOKE DETECTORS	•	•			•	•			•
80 FIRE SPRINKLER WATERFLOW SWITCHES	•	•			•	•			
80 FIRE SPRINKLER VALVE SUPERVISORY SWITCHES	•			•					
80A FIRE SPRINKLER WATERFLOW SWITCH	•	•			•				
80A FIRE SPRINKLER VALVE SUPERVISORY SWITCH	•			•					
AC POWER FAILURE	•		•						
SYSTEM FAULT	•		•						

NOTIFICATION APPLIANCE CIRCUIT CURRENTS

FACILITIES DIVISION

CKT AV1	BASEMENT & 1ST FLOOR	1.550
CKT AV2	2ND FLOOR	2.001
CKT AV3	_	-
CKT AV4		-
CKT AV5	-	_
CKT AV6	-	_
CKT AV7	-	_
CKT AV8	_	_
	TOTAL NOTIFICATION APPLIANCES CURRENT	3.551

DRAWN BY LDD

CHECKED BY LDD

APPROVED BY MCD

SCALE AS NOTED DRAWING NO.

4B80E097

PROJECT NO. 000000

DATE 10/23/2013

10/23/2013

10/23/2013

SHEET

1 OF 1

80, 80A FIRE ALARM SYSTEM AS BUILT FUNCTION CHART & CALCULATIONS UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY LDD LDD MCD 10/23/13 AS BUILT ISSUE (PROGRESS, ESTIMATE, BID, CONSTRUCTION, CONFORMED, REVISION, RECORD)

LDD LDD MCD 10/23/13 AS BUILT REMARKS